



Certificate of Compliance

Certificate: 1114529 (LR 101178-13)

Master Contract: 161479

Project: 70013891

Date Issued: November 12, 2014

Issued to: **Hollyland Company Limited**

**Unit B 31/F Billion Centre, Tower A
1 Wang Kwong Rd
Kowloon Bay,
Hong Kong
Attention: Serene Leong**

*The products listed below are eligible to bear
the CSA Mark shown with adjacent indicator*



Ramana Tangirala

Issued by: Ramana Tangirala

PRODUCTS

CLASS 1422 30 - FUSES - Supplemental Fuses - Component Acceptance

Microfuses, Ceramic Cartridge Fuses, non-renewable:

Type 20N, Pigtail, 2.5 by 7.5mm, 100mA-3A, 125V and 250V ac, IR 125V-50A and 250V-25A.

Type 20N, Pigtail, 2.5 by 7.5mm, 3.15A-10A, 125V and 250V ac, IR 125V-50A and 250V-30A.

Type 20N, Pigtail, 2.5 by 7.5mm, 12A-15A, 72V ac, IR 72V-30A.

APPLICABLE REQUIREMENTS

CSA Std. C22.2 No. 248.1 - Low-Voltage Fuses - Part 1: General Requirements.

CSA Std. C22.2 No. 248.14 - Low-Voltage Fuses, Part 14: Supplemental Fuses

T.I.L. CA-07 - Component Acceptance Requirements for Supplemental Fuses