

Certificate of Compliance

Certificate: 1354612

Master Contract: 161479 (LR 101178)

Project: 1354612

Date Issued: September 3, 2002

Issued to: Hollyland Company Limited
12/F, Flat A, Gee Lok Ind. Bldg.
34, Hung To Road, Kwun Tong
Kowloon
Hong Kong
Attention: Mr. William Wong, President

The products listed below are eligible to bear the CSA Mark shown with adjacent indicator ▲



Issued by:

R. Tangirala, P. Eng.

Authorized by:

Nick Albano
Operations Manager

PRODUCTS

CLASS 1422 30 - FUSES – Supplemental fuses - Component Acceptance

Microfuses, Ceramic Cartridge Fuses, non-renewable:

Type 30N, Pigtail, 4 by 9mm, 100mA-15A, 350V ac, IR 350V-50A.

APPLICABLE REQUIREMENTS

CSA Std. C22.2 No.	248.1	-	Low-Voltage Fuses - Part 1: General Requirements.
CSA Std. C22.2 No.	248.14	-	Low-Voltage Fuses, Part 14: Supplemental Fuses
T.I.L. CA-07		-	Component Acceptance Requirements for Supplemental Fuses