



# Certificate of Compliance

Certificate: 1246936

Master Contract: 161479 (LR 101178)

Project: 1246936

Date Issued: October 1, 2001

Issued to: **HOLLYLAND CO., LTD.**  
 12/F Flat A, Gee Lok Ind., Bldg.  
 34, Hung To Rd., Kwun Tong,  
 Kowloon, Hong Kong  
 Attention: Mr. William Wong, President

*The products listed below are eligible to bear the CSA Mark shown*



Issued by:

*R. Tangirala*  
 R. Tangirala, P.Eng.

Authorized by:

*B. Rossborough*  
 B. Rossborough  
 Operations Manager

## PRODUCTS

**CLASS 1422 30 - SUPPLEMENTAL FUSES - Component Acceptance**

Supplemental, glass cartridge fuses, non-renewable:

- Cat No 52NM or 51NM(P), pigtail lead, rated 32mA-8A, 250V ac and less IR125-10kA, IR250-\*, 5.2 by 20mm.
- Cat No 52S or 51S(P), pigtail lead, 2 rated 32mA-8A, 250V ac and less IR125-10kA, IR250-\*, 5.2 by 20mm.
- Cat No 62NM or 61NM(P), pigtail lead, rated 32mA - 10A, 250V ac and less, IR125-10kA, IR250-\*, 6.35 by 31mm.
- Cat No 62S or 61S(P), pigtail lead, rated 32mA - 5A, 250V ac and less, IR125-10kA, IR250-\*, 6.35 by 31mm.

\* Note: Types with IR250-\* have interrupting ratings of 35A for 1A or less, 100A for more than 1A to 3.5A, 200A for more than 3.5A to 10.0A, as applicable for the ampere ratings listed.

## APPLICABLE REQUIREMENTS

CSA Std. C22.2 No. 248.1  
 CSA Std. C22.2 No. 248.14  
 T.I.L. CA-07

- Low-Voltage Fuses - Part 1: General Requirements.
- Low-Voltage Fuses, Part 14: Supplemental Fuses
- Component Acceptance Requirements for Supplemental Fuses