



Certificate of Compliance

Certificate Number: LR 101178-1

Revision: LR 101178-3

Date Issued: July 29, 1996

- Cat No 61NM and 62NM (pigtail lead) rated 32mA - 10A, 250V ac and less, IR125-10kA, IR250-*, 6.35 by 31mm.

- Cat No 61S and 62S (pigtail lead) rated 32mA - 5A, 250V ac and less, IR125-10kA, IR250-*, 6.35 by 31mm.

* Note: Types with IR250-* have interrupting ratings of 35A for 1A or less, 100A for more than 1A to 3.5A, 200A for more than 3.5A to 10.0A, as applicable for the ampere ratings listed.

APPLICABLE REQUIREMENTS

- C. Std. C22.2 No. 248.14-1994 - Part 14: Low-Voltage Fuses; Part 14:
Supplemental Fuses (UL 248.14)
- UL 248.14-1994 - Low-Voltage Fuses; Part 14: Supplemental Fuses